STAR GRACE CHEMICAL PTE LTD
ADD: 73 UPPER PAYA LEBAR ROAD #06-01C CENTRO BIANCO Singapore 534818
E-mail:maggiewang@stargrace-chemical.com Web: www.stargrace-chemical.com
TEL:+86-411-3901-3010 TEL: +86-411-3904-9790

CERTIFICATE OF ANALYSIS

PRODUCT: Refrigerant R22

THIS IS CERTIFY THAT WE, THE UNDERSIGNED HAVE INSPECTED THE QUALITY OF THE ABOVE MENTIONED GOODS AND FOUND THE RESULT OF INSPECTION AS FOLLOWS：

Project	Type I index		Type II
	Superior product	First-class product	
purity, %≥	99.9	99.6	99.95
moisture, %≥	0.0010	0.0030	0.0020
acidity(in HCL), %≥	0.00001	0.0001	0.0001
evaporated residue, %≥	0.010		
Chloride,%	Pass		
Foul Gas in Air Phase, % ≤	1.5		
0 2 Gas phase (25 c c)%, by volume %, ≤			0.005
Note: Type i is used for refrigerants			

QUALITY CONTROL DEPT. MANAGER: L. Mai

STAR GRACE CHEMICAL PTE. LTD. CO. REG. NO: 202021086H

Maggie Wang